



1AL1 PZ30-15		1AL1		负荷名称	图号及接入编号	控制数量	容量kw	计算电流	回路号
Bv4×4+1×2.5 WE/PR	Dz47-63D20/3P	Dz47-63D10/3P	Rvv (5×1.5) WE/PR	风淋室	⑨ F1	1台	2.2	4.2	W1
来自车间顶照明、通风电路 Pe=7.1Kw Kx=0.65 Cosφ=0.9 Pjs=4.6Kw Ijs=8.3A		Dz47LE-32C16/2P30mA	Bv2×4+1×2.5 WE/PR	插座	⑧ N11~N14 ⑧ 1N2.4	5个	3	13.5	W2
		Dz47-63c10/1P	Bv3×2.5 WE/PR	物流大门	⑨ N11	1套	0.5	2.8	W3
		Dz47-63c10/1P	Bv3×2.5 WE/PR	车间Led照明	⑨ k15~k16	16盏	1.1	4.0	W4
		Dz47-63c6/1P	Bv3×2.5 WE/PR	通道、更衣照明+风扇	⑨ k11~k14	4盏+1 风扇	0.2	1.2	W5
		Dz47-63c6/1P	Bv3×2.5 WE/PR	定时紫外杀菌灯	⑨ 2H1	2	0.1	0.5	W6

1AL2 PZ30-15				负荷名称	图号及接入编号	控制数量	容量kw	计算电流	回路号
Bv4×4+1×2.5 WE/PR	Dz47-63D20/3P	Dz47-63D10/3P	Rvv (5×1.5) WE/PR	风淋室	⑨ F2	1台	2.2	4.2	W21
来自车间顶照明、通风电路 Pe=6.1Kw Kx=0.65 Cosφ=0.9 Pjs=4Kw Ijs=7.2A		Dz47LE-32C16/2P30mA	Bv2×4+1×2.5 WE/PR	插座	⑧ N21~N26 ⑧ 3N2.4	7个	3	13.5	W22
		Dz47-63c6/1P	Bv3×2.5 WE/PR	更衣照明+风扇	⑨ k21~k23	4盏+1 风扇	0.2	1.2	W23
		Dz47-63c6/1P	Bv3×2.5 WE/PR	车间Led照明	⑨ k24~k26	8盏	0.55	2.0	W24
		Dz47-63c6/1P	Bv3×2.5 WE/PR	定时紫外杀菌灯	⑨ 2H2	3	0.1	0.5	W25

1AL3 PZ30-15				负荷名称	图号及接入编号	控制数量	容量kw	计算电流	回路号
Bv4×4+1×2.5 WE/PR	Dz47-63D20/3P	Dz47-63D10/3P	Rvv (5×1.5) WE/PR	风淋室	⑨ F3	1台	2.2	4.2	W31
来自车间顶照明、通风电路 Pe=6.4Kw Kx=0.65 Cosφ=0.9 Pjs=4.2Kw Ijs=7.6A		Dz47LE-32C16/2P30mA	Bv2×4+1×2.5 WE/PR	插座	⑧ N31~N36 ⑧ 3N2.4~2N2.4	8个	3	13.5	W32
		Dz47-63c6/1P	Bv3×2.5 WE/PR	更衣照明+风扇	⑨ k31~k35	3盏+2 风扇	0.32	1.85	W33
		Dz47-63c10/1P	Bv3×2.5 WE/PR	车间Led照明	⑨ k36~k38	11盏	0.75	2.75	W34
		Dz47-63c6/1P	Bv3×2.5 WE/PR	定时紫外杀菌灯	⑨ 2H3	3	0.1	0.5	W35

13、⑨-a. 照明、插座、换风、杀菌，电路原理图